

DOC11R

**Case Management System - KY Public Service Commission***Regular Cases Before the Commission as of February 23, 2025***2009-00253**

RECEIVED: 12/31/08

FILED: 07/07/09

FINAL: 10/05/11

REOPENED:

SUSPENSION DATE:

CASE NATURE: Request to Deviate from 807 KAR 5:066, Section 16(1)

**CASE CODE**Deviation  
Electronic Case**UTILITIES:**

Kentucky-American Water Company

**HEARINGS:**12/02/10 Informal Conference  
05/12/10 Informal Conference**INDEX OF EVENTS:**

03/27/14 POST CASE: Kentucky-American Water Company's Ordering Paragraph 6 Report  
03/29/13 POST CASE: Kentucky-American Water Company Ordering Paragraph 6 Report  
10/05/11 Order Entered:  
(1) Kentucky-American's application to deviate from 807 KAR 5:066, Section 16(1) is granted.  
(2) Kentucky-American is permitted to keep its 5/8-inch meters in service for 15 years without testing for accuracy.  
(3) Kentucky-American shall remove its 5/8-inch meters at or before their 15-year mark and shall store them for a minimum of three months after removal so that they will be available for testing.  
(4) Kentucky-American shall have the burden of proof regarding the accuracy of any 5/8-inch meter that has been removed after 15 years of service and has been discarded without being tested for accuracy.  
(5) For calendar years 2012 and 2013, Kentucky-American shall test a random sample of 200 5/8-inch meters that are removed from service after 15 years pursuant to this Order.  
(6) On or before March 31 of 2013 and 2014, Kentucky-American shall file with the Commission a written report containing the test results of the 200 15 year 5/8-inch meters tested during the prior calendar year.  
(7) Nothing contained in this Order shall limit the Commission's authority to review the authorized deviation while the deviation remains in effect.

05/16/11 Order Entered:  
(1) KAWC shall have ten days from the date of this Order to present any comments or to request a hearing.  
(2) In a request for hearing is submitted, KAWC, in its request, shall identify the issues it wishes to raise at a hearing, the witnesses it intends to present, and an explanation of why a hearing on these issues is necessary.  
(3) If no request a hearing is received, this matter shall stand submitted for decision.

02/28/11 Kentucky-American Water Company KAWs response to Staffs supplemental information request  
02/08/11 Notice of Extension of Time to Reply to Commission Staff's Follow-Up Request  
01/14/11 Kentucky-American Water Company Letter Requesting Extension  
12/21/10 Memorandum dated 12/20/10 for Informal Conference of 12/02/10; Comments, if any, due within five days of receipt  
06/21/10 KY American Water's Responses to PSC Staff's First Set of Information Requests  
06/18/10 Kentucky-American Water Company KAWs Responses to Commission Staffs First Data Request  
05/19/10 Notice of Extension of Time to Reply to Data Request  
05/17/10 Memorandum dated 5/17/10 for Informal Conference of 5/12/10; Comments, if any, due within five days of receipt  
05/11/10 Commission Staff's Notice of Informal Conference  
04/27/10 Kentucky-American Water Company Request Regarding Staff Data Request  
04/27/10 Kentucky-American Water Company Request Regarding Staff Data Request (Original/Electronic Receipt)  
04/22/10 Commission Staff's First Data Request to Kentucky-American Water Company  
07/07/09 Order Entered:  
(1) Docket is established to consider Kentucky-American's application for a deviate from 807 KAR

DOC11R

## Case Management System - KY Public Service Commission

*Regular Cases Before the Commission as of February 23, 2025*

5:066, Section 16(1) to permit its 5/8-inch meters to remain in service for up to 15 years without testing.  
(2) The records of Cases No. 1996-00569 and No. 2007-00198 are incorporated by reference into the record of this proceeding.

03/09/09  
12/31/08

Kentucky-American's amended request for permission to deviate from 807 KAR 5:066, Section 16(1)  
Kentucky-American Water Company's request for permission to deviate from 807 KAR 5:066, Section 16(1)

---

Total Number of Cases: 1